Installation Guidance

Deck timed basin tap – 15 seconds

B&M SKU ID08410 | Idral code 08410

Installation sequence

1. Have a qualified installer follow the original model diagrams and prepare the water connections. Purge the supply pipes before connection and provide suitable water filtration.

2. Install the tap on the basin deck using its model fixing arrangement and connect the single water supply.

3. Open the water supply and check every connection for leaks. Test the push button and automatic closure; the model-specific nominal cycle is 15 seconds at 3 bar.

Important

Operating range: 1–6 bar, recommended 2–4 bar; water temperature 5–65 °C. Protect the valve from freezing.

The Technical Specification gives the exact variant duration and tolerance; use it alongside the generic timed-tap manual.

Source: Idral ISTA02-01. This summary accompanies the original manufacturer instructions supplied separately. Read the original instructions for complete safety information, model diagrams and service procedures.