Installation Guidance

Concealed timed urinal tap – 8 seconds

B&M SKU ID08425 | Idral code 08425

Installation sequence

1. Have a qualified installer follow the original model diagrams and prepare the water connections. Purge the supply pipes before connection and provide suitable water filtration.

2. Prepare the concealed housing and connect the inlet and outlet using the Technical Specification. Protect the valve during masonry work and retain service space within the cover-plate area, then fit the cover and push button.

3. Open the water supply and check every connection for leaks. Test the push button and automatic closure; the model-specific nominal cycle is 8 seconds at 3 bar.

Important

Operating range: 1–6 bar, recommended 2–4 bar; water temperature 5–65 °C. Protect the valve from freezing.

The Technical Specification gives the exact variant duration and tolerance; use it alongside the generic timed-tap manual.

Source: Idral ISTA02-01. This summary accompanies the original manufacturer instructions supplied separately. Read the original instructions for complete safety information, model diagrams and service procedures.