Installation Guidance

Wall timed shower tap – 25 seconds

B&M SKU ID08430-30 | Idral code 08430-30

Installation sequence

1. Have a qualified installer follow the original model diagrams and prepare the water connections. Purge the supply pipes before connection and provide suitable water filtration.

2. Install the exposed wall tap on a smooth, flat surface and connect the inlet and outlet according to the Technical Specification.

3. Open the water supply and check every connection for leaks. Test the push button and automatic closure; the model-specific nominal cycle is 25 seconds at 3 bar.

Important

Operating range: 1–6 bar, recommended 2–4 bar; water temperature 5–65 °C. Protect the valve from freezing.

The Technical Specification gives the exact variant duration and tolerance; use it alongside the generic timed-tap manual.

Source: Idral ISTA02-01. This summary accompanies the original manufacturer instructions supplied separately. Read the original instructions for complete safety information, model diagrams and service procedures.